



---

**Dallas County**  
IFB 2026-041-7126

**Central Trail Extension**  
**Vendor Questions and Answers**

**Q&A:**

- 1. Missing from plans: (Part B): 0.07A (it is a duplicate of sheet 0.04B instead.)  
Missing from specs: (Dallas County Public Works Dept Special Specifications)  
Item DC-0504.**

A: Dallas County will revise the plan set to: remove duplicate Sheet 0.04B, insert Sheet 0.07A (Civil Abbreviations – Sheet 1 of 2) in the correct location, and correct the sheet number on Page 180. These changes will be included in an addendum and the updated plan set will be uploaded to BidNet.

Regarding Dallas County Public Works Department Special Specification Item DC-0504, this item is included in the bid book. Please refer to pages 243–247 of the bid book specifications.

- 2. Can Methly Methacrylate (MMA) be used in lieu of thermoplastic paint for striping over the concrete surface? 2. MMA is a much more durable material and bonds to concrete much better than thermoplastic. TxDOT has approved it on multiple jobs. It's also been used for jobs in the city of Richardson.**

A: Since MMA has reportedly been approved by TxDOT and has been used on projects for the City of Richardson, its use would appear to be acceptable. However, once the project has been awarded, please submit the proposed material substitution as an RFI for review. We will coordinate with TxDOT and the applicable cities to confirm acceptability and provide final approval prior to its use.

- 3. While reviewing the removal plans, we noticed the trees designated for removal are shown only as grouped callouts. Could you please provide a tree survey or tree disposition schedule identifying each tree designated for removal, including the diameter of each tree?**

A: Tree Disposition Schedule will be prepared and included as an additional plan sheet. The schedule will identify each tree proposed for removal and include the

---



---

corresponding diameter for each tree, providing the requested level of detail for bidding purposes.

**4. Has a location been selected for the field office?**

A: The field office location has not been selected at this time. Once the project is awarded, Dallas County will coordinate with the selected contractor to determine an appropriate field office location.

**5. How would you like us to fill out the SBE forms that are required to be submitted in the bidnet portal, since there isn't a goal for this project? Do we just put "N/A" on all SBE forms?**

A: Yes, you may indicate "N/A" on the SBE forms, unless you intend to utilize any certified SBE firms.

**6. Are the DART fees and flagger fees part of the DART Force Account item or are they a separate cost to contractors?**

A: Yes, Roadway Worker Protection and Flagging fees are included in the Schedule 8 bid item. Other fees are not included in the allowance for Schedule 8.

---